


# OSQ™ LED Area/Flood Luminaire featuring Patented NanoComfort® Technology – Version C

## Photometry


All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:

<https://creelighting.com/products/outdoor/area/osq-series>

### 2M



RESTL Test Report #: PL17910-001A  
Configured  
OSQL-C-xxL-30K7-2M-UL-xx-xx-xx  
Initial Delivered Lumens: 27,400



OSQL-C-30L-30K7-2M-UL  
Mounting Height: 25' (7.6m) A.F.G.  
Initial Delivered Lumens: 27,400  
Initial FC at grade


### Type II Mid Distribution

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	3,650	B1 U0 G1	3,800	B1 U0 G1	2,810	B1 U0 G1	3,800	B1 U0 G1
6L	5,475	B1 U0 G1	5,700	B1 U0 G1	4,220	B1 U0 G1	5,700	B1 U0 G1
9L	8,225	B2 U0 G2	8,550	B2 U0 G2	6,325	B2 U0 G2	8,550	B2 U0 G2
11L	10,025	B2 U0 G2	10,450	B2 U0 G2	7,750	B2 U0 G2	10,450	B2 U0 G2
16L	14,650	B3 U0 G3	15,200	B3 U0 G3	11,275	B2 U0 G2	15,200	B3 U0 G3
22L	20,100	B3 U0 G3	20,900	B3 U0 G3	15,500	B3 U0 G3	20,900	B3 U0 G3
30L	27,400	B3 U0 G3	28,500	B3 U0 G3	21,100	B3 U0 G3	28,500	B3 U0 G3
40L	36,500	B4 U0 G4	38,000	B4 U0 G4	28,100	B3 U0 G3	38,000	B4 U0 G4
50L	45,600	B4 U0 G4	47,500	B4 U0 G4	35,200	B3 U0 G3	47,500	B4 U0 G4
65L	59,300	B4 U0 G5	61,800	B4 U0 G5	45,700	B4 U0 G4	61,800	B4 U0 G5
75L	68,400	B5 U0 G5	71,300	B5 U0 G5	52,800	B4 U0 G4	71,300	B5 U0 G5
85L	77,600	B5 U0 G5	80,800	B5 U0 G5	59,800	B4 U0 G5	80,800	B5 U0 G5


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

### 2B



RESTL Test Report #: PL17977-001A  
OSQL-C-40L-30K7-2B-UL-xx-xx-xx  
Initial Delivered Lumens: 25,560



OSQL-C-40L-30K7-2B-UL  
Mounting Height: 25' (7.6m) A.F.G.  
Initial Delivered Lumens: 25,100  
Initial FC at grade

### Type II Mid w/BLS Distribution (factory-installed)

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,510	B1 U0 G1	2,620	B1 U0 G1	1,940	B0 U0 G1	2,620	B1 U0 G1
6L	3,760	B1 U0 G1	3,920	B1 U0 G1	2,900	B1 U0 G1	3,920	B1 U0 G1
9L	5,650	B1 U0 G1	5,875	B1 U0 G1	4,350	B1 U0 G1	5,875	B1 U0 G1
11L	6,900	B1 U0 G1	7,200	B1 U0 G2	5,325	B1 U0 G1	7,200	B1 U0 G2
16L	10,075	B1 U0 G2	10,450	B2 U0 G2	7,750	B1 U0 G2	10,450	B2 U0 G2
22L	13,800	B2 U0 G2	14,375	B2 U0 G2	10,650	B2 U0 G2	14,375	B2 U0 G2
30L	18,800	B2 U0 G2	19,600	B2 U0 G3	14,525	B2 U0 G2	19,600	B2 U0 G3
40L	25,100	B3 U0 G3	26,200	B3 U0 G3	19,400	B2 U0 G2	26,200	B3 U0 G3
50L	31,400	B3 U0 G4	32,700	B3 U0 G4	24,200	B3 U0 G3	32,700	B3 U0 G4
65L	40,800	B3 U0 G4	42,500	B3 U0 G4	31,500	B3 U0 G4	42,500	B3 U0 G4
75L	47,100	B3 U0 G5	49,000	B3 U0 G5	36,300	B3 U0 G4	49,000	B3 U0 G5

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
Advanced Lighting Technologies New Zealand Ltd  
Advanced Lighting Technologies Asia Pte Ltd

Australia  
New Zealand  
Singapore

+61 3 9800 5600  
+64 9 415 6332  
+65 6844 2338


[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)

## Revision Date: 16/08/2024


## Photometry

All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:  
<https://creelighting.com/products/outdoor/area/osq-series>

### 3B



RESTL Test Report #: PL17975-001A  
 OSQ-L-C-40L-30K7-3B-UL-xx-xx-xx  
 Initial Delivered Lumens: 25,199



OSQ-L-C-40L-30K7-3B-UL  
 Mounting Height: 25' (7.6m) A.F.G.  
 Initial Delivered Lumens: 25,100  
 Initial FC at grade


#### Type III Mid w/BLS Distribution (factory-installed)

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,510	B1 U0 G1	2,620	B1 U0 G1	1,940	B0 U0 G1	2,620	B1 U0 G1
6L	3,760	B1 U0 G1	3,920	B1 U0 G1	2,900	B1 U0 G1	3,920	B1 U0 G1
9L	5,650	B1 U0 G1	5,875	B1 U0 G2	4,350	B1 U0 G1	5,875	B1 U0 G2
11L	6,900	B1 U0 G2	7,200	B1 U0 G2	5,325	B1 U0 G1	7,200	B1 U0 G2
16L	10,075	B1 U0 G2	10,450	B2 U0 G2	7,750	B1 U0 G2	10,450	B2 U0 G2
22L	13,800	B2 U0 G2	14,375	B2 U0 G2	10,650	B2 U0 G2	14,375	B2 U0 G2
30L	18,800	B2 U0 G3	19,600	B2 U0 G3	14,525	B2 U0 G2	19,600	B2 U0 G3
40L	25,100	B3 U0 G4	26,200	B3 U0 G4	19,400	B2 U0 G3	26,200	B3 U0 G4
50L	31,400	B3 U0 G4	32,700	B3 U0 G4	24,200	B3 U0 G3	32,700	B3 U0 G4
65L	40,800	B3 U0 G5	42,500	B3 U0 G5	31,500	B3 U0 G4	42,500	B3 U0 G5
75L	47,100	B3 U0 G5	49,000	B3 U0 G5	36,300	B3 U0 G4	49,000	B3 U0 G5


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

### 3M W/OSQ\*-C-BLSF



RESTL Test Report #: PL17976-001A  
 OSQ-L-C-40L-30K7-3M-UL-xx-xx-xx w/  
 OSQ-L-C-BLSF  
 Initial Delivered Lumens: 22,081



OSQ-L-C-40L-30K7-3M-UL w/OSQ-L-C-BLSF  
 Mounting Height: 25' (7.6m) A.F.G.  
 Initial Delivered Lumens: 21,000  
 Initial FC at grade

#### Type III Mid Distribution w/OSQ\*-C-BLSF (field-installed)

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,100	B0 U0 G1	2,180	B0 U0 G1	1,610	B0 U0 G1	2,180	B0 U0 G1
6L	3,140	B1 U0 G1	3,270	B1 U0 G1	2,420	B1 U0 G1	3,270	B1 U0 G1
9L	4,720	B1 U0 G1	4,910	B1 U0 G1	3,630	B1 U0 G1	4,910	B1 U0 G1
11L	5,750	B1 U0 G2	6,000	B1 U0 G2	4,450	B1 U0 G1	6,000	B1 U0 G2
16L	8,400	B1 U0 G2	8,725	B1 U0 G2	6,475	B1 U0 G2	8,725	B1 U0 G2
22L	11,550	B2 U0 G2	12,000	B2 U0 G2	8,900	B1 U0 G2	12,000	B2 U0 G2
30L	15,700	B2 U0 G3	16,400	B2 U0 G3	12,100	B2 U0 G2	16,400	B2 U0 G3
40L	21,000	B2 U0 G3	21,800	B3 U0 G3	16,100	B2 U0 G3	21,800	B3 U0 G3
50L	26,200	B3 U0 G4	27,300	B3 U0 G4	20,200	B2 U0 G3	27,300	B3 U0 G4
65L	34,000	B3 U0 G4	35,500	B3 U0 G5	26,200	B3 U0 G4	35,500	B3 U0 G5
75L	39,300	B3 U0 G5	40,900	B3 U0 G5	30,300	B3 U0 G4	40,900	B3 U0 G5
85L	44,500	B3 U0 G5	46,400	B3 U0 G5	34,300	B3 U0 G4	46,400	B3 U0 G5

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
 Advanced Lighting Technologies New Zealand Ltd  
 Advanced Lighting Technologies Asia Pte Ltd

Australia  
 New Zealand  
 Singapore

+61 3 9800 5600  
 +64 9 415 6332  
 +65 6844 2338

[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)


# OSQ™ LED Area/Flood Luminaire featuring Patented NanoComfort® Technology – Version C

## Photometry


All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:

<https://creelighting.com/products/outdoor/area/osq-series>

### 4M



RESTL Test Report #: PL18130-001A  
Configured  
OSQ-C-xxL-40K7-4M-UL-xx-xx-xx  
Initial Delivered Lumens: 38,000



OSQ-C-40L-40K7-4M-UL  
Mounting Height: 25' (7.6m) A.F.G.  
Initial Delivered Lumens: 38,000  
Initial FC at grade


### Type IV Mid Distribution

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	3,650	B1 U0 G1	3,800	B1 U0 G1	2,810	B1 U0 G1	3,800	B1 U0 G1
6L	5,475	B1 U0 G1	5,700	B1 U0 G1	4,220	B1 U0 G1	5,700	B1 U0 G1
9L	8,225	B2 U0 G2	8,550	B2 U0 G2	6,325	B1 U0 G1	8,550	B2 U0 G2
11L	10,025	B2 U0 G2	10,450	B2 U0 G2	7,750	B2 U0 G2	10,450	B2 U0 G2
16L	14,650	B3 U0 G2	15,200	B3 U0 G2	11,275	B2 U0 G2	15,200	B3 U0 G2
22L	20,100	B3 U0 G3	20,900	B3 U0 G3	15,500	B3 U0 G2	20,900	B3 U0 G3
30L	27,400	B3 U0 G4	28,500	B3 U0 G4	21,100	B3 U0 G3	28,500	B3 U0 G4
40L	36,500	B4 U0 G4	38,000	B4 U0 G4	28,100	B3 U0 G4	38,000	B4 U0 G4
50L	45,600	B4 U0 G5	47,500	B4 U0 G5	35,200	B4 U0 G4	47,500	B4 U0 G5
65L	59,300	B5 U0 G5	61,800	B5 U0 G5	45,700	B4 U0 G5	61,800	B5 U0 G5
75L	68,400	B5 U0 G5	71,300	B5 U0 G5	52,800	B4 U0 G5	71,300	B5 U0 G5
85L	77,600	B5 U0 G5	80,800	B5 U0 G5	59,800	B5 U0 G5	80,800	B5 U0 G5


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

### 4B



RESTL Test Report #: PL18145-001A  
Configured  
OSQ-C-xxL-40K7-4B-UL-xx-xx-xx  
Initial Delivered Lumens: 24,000



OSQ-C-40L-40K7-4B-UL  
Mounting Height: 25' (7.6m) A.F.G.  
Initial Delivered Lumens: 24,000  
Initial FC at grade

### Type IV Mid w/BLS Distribution (factory-installed)

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,300	B1 U0 G0	2,400	B1 U0 G0	1,770	B0 U0 G0	2,400	B1 U0 G0
6L	3,440	B1 U0 G1	3,590	B1 U0 G1	2,660	B1 U0 G0	3,590	B1 U0 G1
9L	5,175	B1 U0 G1	5,400	B1 U0 G1	3,980	B1 U0 G1	5,400	B1 U0 G1
11L	6,325	B1 U0 G1	6,600	B1 U0 G1	4,880	B1 U0 G1	6,600	B1 U0 G1
16L	9,225	B2 U0 G2	9,575	B2 U0 G2	7,100	B1 U0 G1	9,575	B2 U0 G2
22L	12,625	B2 U0 G2	13,175	B2 U0 G2	9,750	B2 U0 G2	13,175	B2 U0 G2
30L	17,200	B3 U0 G2	18,000	B3 U0 G2	13,300	B2 U0 G2	18,000	B3 U0 G2
40L	23,000	B3 U0 G3	24,000	B3 U0 G3	17,700	B3 U0 G2	24,000	B3 U0 G3
50L	28,700	B3 U0 G3	29,900	B3 U0 G3	22,200	B3 U0 G3	29,900	B3 U0 G3
65L	37,400	B3 U0 G4	38,900	B3 U0 G4	28,800	B3 U0 G3	38,900	B3 U0 G4
75L	43,100	B4 U0 G4	44,900	B4 U0 G4	33,200	B3 U0 G4	44,900	B4 U0 G4

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
Advanced Lighting Technologies New Zealand Ltd  
Advanced Lighting Technologies Asia Pte Ltd

Australia  
New Zealand  
Singapore

+61 3 9800 5600  
+64 9 415 6332  
+65 6844 2338


[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)

## Photometry


All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:

<https://creelighting.com/products/outdoor/area/osq-series>

### 4M W/OSQ-\*-C-BLSF



**RESTL Test Report #:** PL18144-001A Configured  
OSQ-C-xxL-40K7-4M-UL-xx-xx-xx w/  
OSQ-L-C-BLSF  
**Initial Delivered Lumens:** 21,800




**OSQ-C-40L-40K7-4M-UL w/OSQ-L-C-BLSF**  
**Mounting Height:** 25' (7.6m) A.F.G.  
**Initial Delivered Lumens:** 21,800  
Initial FC at grade

Type IV Mid Distribution w/OSQ-*-C-BLSF (field-installed)								
Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,100	B1 U0 G1	2,180	B1 U0 G1	1,610	B0 U0 G1	2,180	B1 U0 G1
6L	3,140	B1 U0 G1	3,270	B1 U0 G1	2,420	B1 U0 G1	3,270	B1 U0 G1
9L	4,720	B1 U0 G1	4,910	B1 U0 G1	3,630	B1 U0 G1	4,910	B1 U0 G1
11L	5,750	B1 U0 G2	6,000	B1 U0 G2	4,450	B1 U0 G1	6,000	B1 U0 G2
16L	8,400	B1 U0 G2	8,725	B2 U0 G2	6,475	B1 U0 G2	8,725	B2 U0 G2
22L	11,550	B2 U0 G2	12,000	B2 U0 G2	8,900	B2 U0 G2	12,000	B2 U0 G2
30L	15,700	B2 U0 G3	16,400	B2 U0 G3	12,100	B2 U0 G2	16,400	B2 U0 G3
40L	21,000	B3 U0 G3	21,800	B3 U0 G3	16,100	B2 U0 G3	21,800	B3 U0 G3
50L	26,200	B3 U0 G4	27,300	B3 U0 G4	20,200	B3 U0 G3	27,300	B3 U0 G4
65L	34,000	B3 U0 G4	35,500	B3 U0 G4	26,200	B3 U0 G4	35,500	B3 U0 G4
75L	39,300	B3 U0 G5	40,900	B3 U0 G5	30,300	B3 U0 G4	40,900	B3 U0 G5
85L	44,500	B4 U0 G5	46,400	B4 U0 G5	34,300	B3 U0 G4	46,400	B4 U0 G5


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

## AF



**RESTL Test Report #:** PL18039-001A  
OSQM-C-16L-50K9-AF-UL-xx-xx-xx  
**Initial Delivered Lumens:** 12,361



**OSQ-C-40L-40K7-AF-UL**  
**Mounting Height:** 25' (7.6m) A.F.G.  
**Initial Delivered Lumens:** 38,000  
Initial FC at grade

Automotive FrontLineOptic™ Distribution								
Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	3,650	B1 U0 G1	3,800	B1 U0 G1	2,810	B1 U0 G0	3,800	B1 U0 G1
6L	5,475	B1 U0 G1	5,700	B1 U0 G1	4,220	B1 U0 G1	5,700	B1 U0 G1
9L	8,225	B1 U0 G1	8,550	B1 U0 G1	6,325	B1 U0 G1	8,550	B1 U0 G1
11L	10,025	B2 U0 G1	10,450	B2 U0 G1	7,750	B1 U0 G1	10,450	B2 U0 G1
16L	14,650	B2 U0 G2	15,200	B2 U0 G2	11,275	B2 U0 G1	15,200	B2 U0 G2
22L	20,100	B3 U0 G2	20,900	B3 U0 G2	15,500	B2 U0 G2	20,900	B3 U0 G2
30L	27,400	B3 U0 G3	28,500	B3 U0 G3	21,100	B3 U0 G2	28,500	B3 U0 G3
40L	36,500	B3 U0 G3	38,000	B3 U0 G3	28,100	B3 U0 G3	38,000	B3 U0 G3
50L	45,600	B4 U0 G3	47,500	B4 U0 G3	35,200	B3 U0 G3	47,500	B4 U0 G3
65L	59,300	B4 U0 G3	61,800	B4 U0 G3	45,700	B4 U0 G3	61,800	B4 U0 G3
75L	68,400	B4 U0 G4	71,300	B4 U0 G4	52,800	B4 U0 G3	71,300	B4 U0 G4
85L	77,600	B4 U0 G4	80,800	B5 U0 G4	59,800	B4 U0 G3	80,800	B5 U0 G4

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
Advanced Lighting Technologies New Zealand Ltd  
Advanced Lighting Technologies Asia Pte Ltd

Australia  
New Zealand  
Singapore


+61 3 9800 5600  
+64 9 415 6332  
+65 6844 2338

[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)


## Photometry

All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:  
<https://creelighting.com/products/outdoor/area/osq-series>

### AB



RESTL Test Report #: PL18107-001A  
 Configured  
 OSQ-C-30L-xxL-AB-UL-xx-xx-xx  
 Initial Delivered Lumens: 19,600




OSQ-C-30L-40K7-AB-UL  
 Mounting Height: 25' (7.6m) A.F.G.  
 Initial Delivered Lumens: 19,600  
 Initial FC at grade

Automotive FrontLineOptic™ w/BLS Distribution (factory-installed)								
Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,510	B0 U0 G0	2,620	B0 U0 G0	1,940	B0 U0 G0	2,620	B0 U0 G0
6L	3,760	B1 U0 G0	3,920	B1 U0 G0	2,900	B1 U0 G0	3,920	B1 U0 G0
9L	5,650	B1 U0 G0	5,875	B1 U0 G0	4,350	B1 U0 G0	5,875	B1 U0 G0
11L	6,900	B1 U0 G1	7,200	B1 U0 G1	5,325	B1 U0 G0	7,200	B1 U0 G1
16L	10,075	B1 U0 G1	10,450	B1 U0 G1	7,750	B1 U0 G1	10,450	B1 U0 G1
22L	13,800	B2 U0 G1	14,375	B2 U0 G1	10,650	B1 U0 G1	14,375	B2 U0 G1
30L	18,800	B2 U0 G2	19,600	B2 U0 G2	14,525	B2 U0 G1	19,600	B2 U0 G2
40L	25,100	B3 U0 G2	26,200	B3 U0 G2	19,400	B2 U0 G2	26,200	B3 U0 G2
50L	31,400	B3 U0 G2	32,700	B3 U0 G2	24,200	B3 U0 G2	32,700	B3 U0 G2
65L	40,800	B3 U0 G2	42,500	B3 U0 G2	31,500	B3 U0 G2	42,500	B3 U0 G2
75L	47,100	B3 U0 G3	49,000	B3 U0 G3	36,300	B3 U0 G2	49,000	B3 U0 G3


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

### AF W/OSQ\*-C-BLSF



RESTL Test Report #: PL18108-001A  
 Configured  
 OSQ-C-xxL-40K7-AF-UL-xx-xx-xx w/OSQ-L-C-BLSF  
 Initial Delivered Lumens: 16,400



OSQ-C-30L-40K7-AF-UL w/OSQ-L-C-BLSF  
 Mounting Height: 25' (7.6m) A.F.G.  
 Initial Delivered Lumens: 16,400  
 Initial FC at grade

Automotive FrontLineOptic™ w/OSQ*-C-BLSF (field-installed)								
Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	2,100	B0 U0 G1	2,180	B0 U0 G1	1,610	B0 U0 G1	2,180	B0 U0 G1
6L	3,140	B1 U0 G1	3,270	B1 U0 G1	2,420	B0 U0 G1	3,270	B1 U0 G1
9L	4,720	B1 U0 G1	4,910	B1 U0 G1	3,630	B1 U0 G1	4,910	B1 U0 G1
11L	5,750	B1 U0 G1	6,000	B1 U0 G1	4,450	B1 U0 G1	6,000	B1 U0 G1
16L	8,400	B1 U0 G1	8,725	B1 U0 G1	6,475	B1 U0 G1	8,725	B1 U0 G1
22L	11,550	B1 U0 G1	12,000	B1 U0 G1	8,900	B1 U0 G1	12,000	B1 U0 G1
30L	15,700	B2 U0 G2	16,400	B2 U0 G2	12,100	B1 U0 G1	16,400	B2 U0 G2
40L	21,000	B2 U0 G2	21,800	B2 U0 G2	16,100	B2 U0 G2	21,800	B2 U0 G2
50L	26,200	B3 U0 G2	27,300	B3 U0 G2	20,200	B2 U0 G2	27,300	B3 U0 G2
65L	34,000	B3 U0 G2	35,500	B3 U0 G3	26,200	B3 U0 G2	35,500	B3 U0 G3
75L	39,300	B3 U0 G3	40,900	B3 U0 G3	30,300	B3 U0 G2	40,900	B3 U0 G3
85L	44,500	B3 U0 G3	46,400	B3 U0 G3	34,300	B3 U0 G2	46,400	B3 U0 G3

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
 Advanced Lighting Technologies New Zealand Ltd  
 Advanced Lighting Technologies Asia Pte Ltd

Australia  
 New Zealand  
 Singapore

+61 3 9800 5600  
 +64 9 415 6332  
 +65 6844 2338

[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)


# OSQ™ LED Area/Flood Luminaire featuring Patented NanoComfort® Technology – Version C

## Photometry


All published luminaire photometric testing performed to IES LM-79 standards. To obtain an IES file specific to your project consult:

<https://creelighting.com/products/outdoor/area/osq-series>

### 5L



**RESTL Test Report #:** PL18074-001A Configured  
OSQL-C-xxL-40K7-5L-UL-xx-xx-xx  
**Initial Delivered Lumens:** 30,000



**OSQL-C-30L-40K7-5L-UL**  
**Mounting Height:** 25' (7.6m) A.F.G.  
**Initial Delivered Lumens:** 30,000  
Initial FC at grade


### Type V Long Distribution

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	3,840	B2 U0 G1	4,000	B3 U0 G1	2,960	B2 U0 G1	4,000	B3 U0 G1
6L	5,750	B3 U0 G1	6,000	B3 U0 G1	4,440	B3 U0 G1	6,000	B3 U0 G1
9L	8,650	B3 U0 G2	9,000	B3 U0 G2	6,650	B3 U0 G1	9,000	B3 U0 G2
11L	10,550	B4 U0 G2	11,000	B4 U0 G2	8,150	B3 U0 G2	11,000	B4 U0 G2
16L	15,400	B4 U0 G2	16,000	B4 U0 G2	11,850	B4 U0 G2	16,000	B4 U0 G2
22L	21,100	B5 U0 G3	22,000	B5 U0 G3	16,300	B4 U0 G2	22,000	B5 U0 G3
30L	28,800	B5 U0 G3	30,000	B5 U0 G4	22,200	B5 U0 G3	30,000	B5 U0 G4
40L	38,400	B5 U0 G4	40,000	B5 U0 G4	29,600	B5 U0 G3	40,000	B5 U0 G4
50L	48,000	B5 U0 G5	50,000	B5 U0 G5	37,000	B5 U0 G3	50,000	B5 U0 G5
65L	62,400	B5 U0 G5	65,000	B5 U0 G5	48,100	B5 U0 G5	65,000	B5 U0 G5
75L	72,000	B5 U0 G5	75,000	B5 U0 G5	55,500	B5 U0 G5	75,000	B5 U0 G5
85L	81,600	B5 U0 G5	85,000	B5 U0 G5	62,900	B5 U0 G5	85,000	B5 U0 G5


\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt

### 5M



**RESTL Test Report #:** PL17909-001A Configured  
OSQL-C-xxL-30K7-5M-UL-xx-xx-xx  
**Initial Delivered Lumens:** 28,800



**OSQL-C-30L-30K7-5M-UL**  
**Mounting Height:** 25' (7.6m) A.F.G.  
**Initial Delivered Lumens:** 28,800  
Initial FC at grade

### Type V Mid Distribution

Lumen Package	3000K (70 CRI)		4000K (70 CRI)		5000K (90 CRI)		5700K (70 CRI)	
	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20	Initial Delivered Lumens*	BUG Ratings** Per TM-15-20
4L	3,840	B2 U0 G1	4,000	B2 U0 G1	2,960	B2 U0 G1	4,000	B2 U0 G1
6L	5,750	B3 U0 G1	6,000	B3 U0 G1	4,440	B2 U0 G1	6,000	B3 U0 G1
9L	8,650	B3 U0 G2	9,000	B3 U0 G2	6,650	B3 U0 G1	9,000	B3 U0 G2
11L	10,550	B3 U0 G2	11,000	B3 U0 G2	8,150	B3 U0 G1	11,000	B3 U0 G2
16L	15,400	B4 U0 G2	16,000	B4 U0 G2	11,850	B4 U0 G2	16,000	B4 U0 G2
22L	21,100	B4 U0 G2	22,000	B4 U0 G2	16,300	B4 U0 G2	22,000	B4 U0 G2
30L	28,800	B5 U0 G3	30,000	B5 U0 G3	22,200	B4 U0 G2	30,000	B5 U0 G3
40L	38,400	B5 U0 G4	40,000	B5 U0 G4	29,600	B5 U0 G3	40,000	B5 U0 G4
50L	48,000	B5 U0 G4	50,000	B5 U0 G4	37,000	B5 U0 G4	50,000	B5 U0 G4
65L	62,400	B5 U0 G5	65,000	B5 U0 G5	48,100	B5 U0 G4	65,000	B5 U0 G5
75L	72,000	B5 U0 G5	75,000	B5 U0 G5	55,500	B5 U0 G4	75,000	B5 U0 G5
85L	81,600	B5 U0 G5	85,000	B5 U0 G5	62,900	B5 U0 G5	85,000	B5 U0 G5

\* Initial delivered lumens at 25°C (77°F). Actual production yield may vary between -10 and +10% of initial delivered lumens

\*\* For more information on the IES BUG (Backlight-Uplight-Glare) Rating visit: <https://www.ies.org/wp-content/uploads/2017/03/TM-15-11BUGRatingsAddendum.pdf>. Valid with no tilt



Advanced Lighting Technologies Australia Inc  
Advanced Lighting Technologies New Zealand Ltd  
Advanced Lighting Technologies Asia Pte Ltd

Australia  
New Zealand  
Singapore

+61 3 9800 5600  
+64 9 415 6332  
+65 6844 2338

[www.adlt.com.au](http://www.adlt.com.au)  
[www.adlt.co.nz](http://www.adlt.co.nz)  
[www.adlt.com.sg](http://www.adlt.com.sg)



